


*Slavomir BEBJAK - Boris KVIZDA - Gusztav MAYER - Petr VACHA*

# Decay Heat Removal studies in Gas Cooled Fast Reactor during accidental condition - demonstrator ALLEGRO


# What the ALLEGRO is (reference design):

- 75 MW<sub>th</sub> nominal power
- 260°C core inlet
- 530°C core outlet
- 7 MPa primary pressure
- 2 helium primary loops
- 2 water secondary loops
- 3 DHR loops




# Challenges of DHR studies and improvements

- are related to the use of gas coolant:
  - low thermal inertia of helium
  - low gas-coolant density
  - high core power density



# Initiating event: LOCA + Station Blackout



CATHARE  
calculation

1 inch LOCA


	75 MW		37.5 MW	
Guard vessel backup pressure	0.4 MPa	1.1 MPa	0.4 MPa	1.1 MPa
Maximum cladding temperature	Melting	Melting	Melting	1124 °C

MELCOR  
calculation

10 inch LOCA

# CONCLUSION

- ALLEGRO design is being improved to increase the decay heat removal capabilities in case of a very unlikely transient of LOCA cumulated with a Total Station Blackout



**Thank you  
for your attention**

**VUJE, a.s.**

Okružná 5  
918 64 Trnava  
Slovak Republic

[www.vuje.sk](http://www.vuje.sk)

